



Tentative Interim Amendment

NFPA 70

National Electrical Code®

2005 Edition

Reference: 604.6(A)(1)

TIA 05-1 (NFPA 70)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70, *National Electrical Code®*, 2005 edition. The TIA was processed by the National Electrical Code® Committee, and was issued by the Standards Council on July 15, 2004, with an effective date of August 4, 2004.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Revise first paragraph of 604.6 (A) (1) to read:

(1) Cables. Cable shall be listed Type AC cable or listed Type MC cable containing nominal 600-volt 8 to 12 AWG insulated copper conductors with a bare or insulated copper equipment grounding conductor equivalent in size to the ungrounded conductor. ..(remainder of this section to be unchanged)