

[< Previous](#)

NEC® 2011 Edition

[Next >](#)[Tentative Interim Amendments](#)[Tentative Interim Amendment 11-3](#)

NFPA 70®

National Electrical Code®

2011 Edition

Reference: **625.14****TIA 11-3***(SC 11-10-5/TIA Log #1038)*

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70®, *National Electrical Code*®, 2011 edition. The TIA was processed by Code Making Panel 12 and the National Electrical Code Technical Correlating Committee, and was issued by the Standards Council on October 19, 2011, with an effective date of November 8, 2011.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. *Revise 625.14 as follows:*

625.14 Rating. Electric vehicle supply equipment shall have sufficient rating to supply the load served. Electric vehicle charging loads shall be considered to be continuous loads for the purposes of this article. Where an automatic load management system is used, the maximum electric vehicle supply equipment load on a service or feeder shall be the maximum load permitted by the automatic load management system.

Issue Date: October 19, 2011**Effective Date:** November 8, 2011

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/codelist)

Copyright © 2011 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION