

[< Previous](#)

NEC® 2011 Edition

[Next >](#)[Tentative Interim Amendments](#)[Tentative Interim Amendment 11-4](#)

NFPA 70®

National Electrical Code®

2011 Edition

Reference: [230.44\(5\)](#)**TIA 11-4***(SC 11-10-3/TIA Log #1034)*

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70®, *National Electrical Code*®, 2011 edition. The TIA was processed by Code Making Panel 4 and the National Electrical Code Technical Correlating Committee, and was issued by the Standards Council on October 19, 2011, with an effective date of November 8, 2011.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Delete “*thermoplastic-insulated*” in NEC 230.44(5) as follows:

(5) Single conductors 1/0 and larger with CT rating

Issue Date: October 19, 2011**Effective Date:** November 8, 2011

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/codelist)

Copyright © 2011 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION