



Tentative Interim Amendment

## NFPA<sup>®</sup> 70

### National Electrical Code<sup>®</sup> 2014 Edition

**Reference:** 520.45

**TIA 14-4**

*(SC 14-8-16 / TIA Log #1151)*

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70, *National Electrical Code*<sup>®</sup>, 2014 edition. The TIA was processed by the NEC<sup>®</sup> Code-Making Panel 15 and the National Electrical Code<sup>®</sup> Correlating Committee, and was issued by the Standards Council on August 14, 2014, with an effective date of September 3, 2014.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a public input of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

*1. Revise 520.45 to read as follows:*

**520.45 Receptacles.** Receptacles for electrical equipment on stages shall be rated in amperes. Conductors supplying receptacles shall be in accordance with Articles 310 and 400. Section 406.15 shall not apply.

**Issue Date:** August 14, 2014

**Effective Date:** September 3, 2014

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/codelist](http://www.nfpa.org/codelist))

Copyright © 2014 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION